

2009 Annual Drinking Water Quality Report

ENCANTO REAL UTILITY DISTRICT

Yes, your water is safe to drink



OUR WATER MEETS ALL FEDERAL (EPA) AND STATE REQUIREMENTS

The Texas Commission on Environmental Quality (TCEQ) assessed our system, Encanto Real Utility District (Encanto Real UD), and determined that our water is safe to drink. The analysis was made by using the data in the tables in this report which uses testing results from 2005 through 2009.

Because our water meets all state and federal drinking water health standards for the sampling period, there may not be any health based benefits to purchasing bottled water or point of use devices. Encanto Real UD system identification number is 101-0687. We hope this information helps you become more knowledgeable about what's in your drinking water.

En Español – Este reporte incluye informacion importante sobre el agua para tomar. Si tiene preguntas o discusiones sobre este reporte en espanol, favor de llamar al tel. 281.376.8802 par hablar con una persona bilingue en espanol.

TABLE INFORMATION

The tables contain chemical constituents which have been found in your drinking water. The TCEQ and the Environmental Protection Agency (EPA) require water systems to test up to 97 constituents. Only four regulated and one unregulated constituents were detected in Encanto Real UD's water, and these were well below the maximum contaminant level allowed in drinking water. The agencies do not require some contaminants to be monitored annually because their concentrations are not expected to vary. This report states the results of the most current water testing from 2005 through 2009.



REGULATED INORGANICS									
Year Tested	Contaminant Detected	Unit of Measure	Average Level*	Minimum Level*	Maximum Level*	Allowed (EPA's MCL)	MCLG	Meets Standards	Possible source of Contaminant
2009	Barium	ppm	0.184	0.184	0.184	2.0	2.0	yes	Erosion of natural deposits
2009	Nitrate	ppm	0.160	0.160	0.160	10.0	10.0	yes	Erosion of natural deposits

REGULATED ORGANICS									
Year Tested	Contaminant Detected	Unit of Measure	Average Level*	Minimum Level*	Maximum Level*	Allowed (EPA's MCL)	MCLG	Meets Standards	Possible source of Contaminant
2009	Xylenes	ppb	2.000	2.000	2.000	10000	10000		Painting of water tanks
2009	Ethylbenzene	ppb	0.500	0.500	0.500	700	700		Discharge from petroleum refineries

UNREGULATED INORGANICS									
Year Tested	Contaminant Detected	Unit of Measure	Average Level*	Minimum Level*	Maximum Level*	Allowed (EPA's MCL)	MCLG	Meets Standards	Possible source of Contaminant
2009	Sodium	ppm	27.000	27.000	27.000	no standard set			Erosion of natural deposits

* When there is only one sample, the average, minimum, and maximum will be the same number.

DISINFECTANT RESIDUALS									
Year Tested	Contaminant Detected	Unit of Measure	Average Level	Minimum Level	Maximum Level	MDRL	MDRLG	Meets Standards	Possible source of Contaminant
2009	Free Chlorine	ppm	1.640	0.700	3.20	4.0	4.0		Disinfectant used to control microbes

SECONDARY CONSTITUENTS

Many contaminants (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems.

These constituents are called secondary contaminants and are regulated by the State of Texas, not EPA. The secondary constituents are not causes for health concerns. Therefore, secondaries are not required to be reported in this document, but they may greatly affect the appearance and taste of your water.

ADDITIONAL TESTING

Additional testing is done daily at the water plant and throughout the community at various locations to ensure that a safe level of disinfectant is in the system.

Water samples are sent to an independent state-approved laboratory to verify the absence of harmful bacteria. No such bacteria has been detected in this water system.

THE GREEN CHOICE — TAP WATER

Clean fresh well water is delivered to your home for just pennies a glass without the fuel consumption of trucking or the waste left behind by plastic bottles.



TERMS USED IN THIS REPORT

Contaminant: The technical term for anything else in water except pure water is "contaminant." Technically, pure, fresh orange juice can be considered water which has been "contaminated" by the oil, orange pulp and flavorings in the orange which make it taste so good.

Obviously, some contaminants aren't good and can actually be hazardous to your health at specific levels. Those are the ones that are tested and measured.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL, Max. Contaminant Level: The highest level of a contaminant

allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. MCLs are set at very stringent levels.

MCLG, Max. Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

MRDL, Max. Residual Disinfectant Level: The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG, Max. Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

n/a: not established at this time

ppm - Part per million: One part per million equals one teaspoon in 1,302 gallons, which is enough water to fill a typical bathtub over 40 times.

ppb - Part per billion: One part per billion equals one teaspoon in 1,302,000 gallons, which is enough water to fill a typical bathtub over 40,000 times.

WHAT'S IN THE WATER

In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the EPA's **Safe Drinking Water Hotline**, 1.800.426.4791 or at www.epa.gov/safewater.

Bottled water information may be obtained at: www.nrdc.org/water/drinking/bw/bwinx.asp.



SOURCE WATER ASSESSMENT

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the TCEQ. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions.

The information contained in the assessment allows us to focus our source water protection strategies. Some of this source water assessment information will be available later this year on Texas Drinking Water Watch at dww.tceq.state.tx.us/DWW/. For more information on source water assessments and protection efforts at our system, please contact us.

WHERE YOUR WATER COMES FROM

Encanto Real UD obtains its water from a well here in the District. The 580 foot well draws ground water from the Chicot Aquifer. The District also has an interconnect valve with neighboring Northampton Municipal Utility District which is also governed by the same drinking water regulations as Encanto Real UD.

LEAD AND COPPER — TESTED AT THE CUSTOMER'S TAP (SAMPLES COLLECTED AT 10 HOMES)

Year Tested	Substance	Unit of Measure	90th Percentile	# of Homes Exceeding Action Level	Action Level	Possible Sources of Lead and Copper
2009	Lead	ppb	2.6000	0 of 10	15.0	Corrosion of household plumbing systems;
2009	Copper	ppm	0.1440	0 of 10	1.3	Erosion of natural deposits



USE CHEMICALS SPARINGLY

Pesticides kill insects - all insects, even the good ones.


No one would spread pesticides or fertilize over a body of water, but when you over-apply chemicals the excess washes down the street and eventually into streams and lakes.

Read the label and follow the directions. Choose natural products when possible and protect creeks, lakes and the Gulf — our water.

HOW TO DISPOSE OF GREASE

Please put your grease in a container with a lid and then dispose of in your trash.

Grease can create sewer backups in your household lines and in the District's sewer lines causing expensive repairs.



INFORMATION ON LEAD IN WATER

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children.

Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

SOURCE WATER ASSESSMENT

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the TCEQ. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions.

The information contained in the assessment allows us to focus our source water protection strategies. Some of this source water assessment information will be available later this year on Texas Drinking Water Watch at dww.tceq.state.tx.us/DWW/. For more information on source water assessments and protection efforts at our system, please contact us.



KIDS OF ALL AGES

**BRAIN TICKLERS FUN FACTS
WATER EXPERIMENTS**

at www.groundwateradventures.org



OUTSTANDING PERFORMANCE

Encanto Real UD was awarded an Outstanding Performance Certificate for no violations of the Safe Drinking Water Act bacteriological sampling rule from 2001-2007. The District continues with the same performance record to date.

PUBLIC PARTICIPATION

Encanto Real UD meets at 2:00 p.m. on the third Tuesday of each month at 3700 Buffalo Speedway, Suite 830, Houston. Any last minute cancellations will be posted on the District's bulletin board. Call 281.376.8802 for directions.

HAVE QUESTIONS

If you would like more information about particular health risks or contaminants, you may call the EPA at 1.800.426.4791, or the Harris County Health Department at 713.439.6000. EPA has answers to many questions at www.epa.gov/safewater/ccr/frequentquestions.

The District's Operator, Water District Management (WDM), may also be able to assist you with your questions, 1.866.477.9119.



SPECIAL NOTICE FOR THE ELDERLY, INFANTS, CANCER PATIENTS, PEOPLE WITH HIV/AIDS OR OTHER IMMUNE PROBLEMS:

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS, those that are undergoing treatment with steroids, or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline, 1.800.426.4791.