

# 2018 Annual Drinking Water Quality Report

published in 2019

## LAZY RIVER IMPROVEMENT DISTRICT

*Yes, your water is safe to drink*



### OUR WATER MEETS ALL FEDERAL (EPA) AND STATE REQUIREMENTS

This report is produced to provide information about your water system including the quality of your water, the source of the water, levels of detected contaminants, and compliance with drinking water rules.


The Texas Commission on Environmental Quality (TCEQ) assessed our system, Lazy River Improvement District (Lazy River ID), and determined that our water is safe to drink. The analysis was made by using the data in the tables in this report which uses testing results from 2014 through 2018.

Because our water meets all state and federal drinking water health standards for the sampling period, there may not be any health based benefits to purchasing bottled water or point of use devices. Lazy River ID system identification number is 1700039. Thank you for taking the time to read and learn about the water you drink. We look forward to another year of providing you with safe, reliable water.

**En Español – Este reporte incluye informacion importante sobre el agua para tomar. Si tiene preguntas o discusiones sobre este reporte en espanol, favor de llamar al tel. 281.376.8802 par hablar con una persona bilingue en espanol.**

### TRACK YOUR WATER USAGE

Your water bill contains helpful information on a 12-month chart. You can also compare your water usage to other residents in the District. In the middle column at the top of your bill is the average of Lazy River's 230 homes water usage for the month.



Avg. monthly usage in Lazy River is 6,476 gals.

**TABLE INFORMATION** The tables contain chemical constituents which have been found in your drinking water. The TCEQ and the Environmental Protection Agency (EPA) require water systems to test up to 97 constituents. Only eight regulated constituents were detected in Lazy River ID's water, and these were well below the maximum contaminant level allowed in drinking water.

The agencies do not require some contaminants to be monitored annually because their concentrations are not expected to vary. This report, also referred to as a Consumer Confidence Report (CCR), states the results of the most current water testing from 2014 through 2018.

INORGANICS - REGULATED									
Year Tested	Contaminant Detected	Unit of Measure	Average Level*	Minimum Level*	Maximum Level*	Allowed (EPA's MCL)	MCLG	Meets Standards	Possible source of Contaminant
2018	Arsenic	ppb	1.100	0.000	2.200	10.0	0.0	yes	Erosion of natural deposits
2018	Barium	ppm	0.1467	0.0554	0.238	2.0	2.0	yes	Erosion of natural deposits
2018	Fluoride	ppm	0.225	0.160	0.290	4.0	4.0	yes	Erosion of natural deposits
2018	Nitrate	ppm	0.160	0.000	0.240	10.0	10.0	yes	Erosion of natural deposits
2012-18	Combined Radium 226 & 228	pCi/L	1.690	1.080	2.300	5.0	0.0	yes	Erosion of natural deposits
2018	Gross beta emitters	pCi/L	2.900	0.000	5.800	50.0	0.0	yes	Erosion of natural deposits
2018	Gross alpha	pCi/L	3.900	0.000	7.800	15.0	0.0	yes	Erosion of natural deposits
ORGANICS - REGULATED									
2018	Xylenes	ppb	0.350	0.000	7.000	10,000.0	10,000.0	n/a	Erosion of natural deposits

\* When there is only one sample, the average, minimum, and maximum will be the same number.

DISINFECTANT RESIDUALS								
Year	Constituent	Unit	Average	Minimum	Maximum	MRDL	MRDLG	Source
2018	Free Chlorine	ppm	1.15	0.80	2.00	4.0	4.0	Disinfectant used to control microbes

SECONDARY CONSTITUENTS - UNREGULATED									
Year Tested	Contaminant Detected	Unit of Measure	Average Level	Minimum Level	Maximum Level	Allowed (EPA's MCL)	MCLG	Meets Standards	Possible source of Contaminant
2018	Sodium	ppm	47.695	8.390	87.000	n/a	n/a	n/a	Erosion of natural deposits

**SECONDARY CONSTITUENTS** Many contaminants (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. These constituents are called secondary contaminants and are regulated by the State of Texas, not EPA. The secondary constituents are not necessarily causes for health concerns. Therefore, secondaries are not required to be reported in this document, but they may greatly affect the appearance and taste of your water.

**ADDITIONAL TESTING** Additional testing is done daily at the water plant and throughout the community at various locations to ensure that a safe level of disinfectant is in the system. Water samples are sent to an independent state approved laboratory to verify the absence of harmful bacteria. No such bacteria has been detected in this water system.

### TERMS USED IN THIS REPORT

**Contaminant:** The technical term for anything else in water except pure water is "contaminant." Technically, pure, fresh orange juice can be considered water which has been "contaminated" by the oil, orange pulp and flavorings in the orange which make it taste so good.

Obviously, some contaminants aren't good and can actually be hazardous to your health at specific levels. Those are the ones that are tested and measured.

**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

#### MCL, Max. Contaminant Level:

The highest level of a contaminant allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. MCLs are set at very stringent levels.

**MCLG, Max. Contaminant Level Goal:** The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

**MRDL, Max. Residual Disinfectant Level:** The highest level of disinfectant allowed in drinking water.

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**UNREGULATED CONTAMINANTS** The District participated in gathering data under the Unregulated Contaminant Monitoring Rule (UCMR) in order to assist EPA in determining the occurrence of possible drinking water contaminants.

No unregulated contaminants were detected. Additional information may be found on EPA's web site at [www.epa.gov/safewater/data/ncod](http://www.epa.gov/safewater/data/ncod), or you can call the Safe Drinking Water Hotline at 1.800.426.4791.



Shaking the handle will not fix the leak.

Repairing leaks can save hundreds of gallons of water a day.

#### MRDLG, Max. Residual Disinfectant Level Goal:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

n/a: not established at this time

pCi/L: PicoCuries per liter

ppm - Part per million: One part per million equals one teaspoon in 1,302 gallons, which is enough water to fill a typical bathtub over 40 times.

ppb - Part per billion: One part per billion equals one teaspoon in 1,302,000 gallons, which is enough water to fill a typical bathtub over 40,000 times.

## WHAT'S IN THE WATER

The EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants.

The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline, 1.800.426.4791, or at the following web site: [www.epa.gov/safewater](http://www.epa.gov/safewater).

## WHERE YOUR WATER COMES FROM

Lazy River ID obtains its water from a well here in the District. The new water plant, constructed in 2011, is located outside the boundaries of the 100 year flood plain.


The new well reduces water outages due to flooding. A second well is used only for emergency situations. The wells draw ground water from the Evangeline and Chico Aquifers.

## INFORMATION ON LEAD IN WATER

Lazy River is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components in your home or business.

LEAD AND COPPER — TESTED AT THE CUSTOMER'S TAP (SAMPLES COLLECTED FROM 10 HOMES)

Year Tested	Substance	Unit of Measure	90th Percentile	No. of Homes Exceeding Action Level	Action Level	Possible Sources of Lead and Copper
2018	Lead	ppb	4.840	0 of 10	15.0	Corrosion of household plumbing systems and erosion of natural deposits
2018	Copper	ppm	0.045	0 of 10	1.3	



When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.

If you are concerned about lead in your water, you may wish to have your water tested.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## SOURCES OF DRINKING WATER

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

## SOURCE WATER ASSESSMENT

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Water District Management at 281.376.8802.



- ♻️ ReUse - RePurpose - ReCycle everything you can.
- ♻️ Keep trash out of streets and storm drains.
- ♻️ Use reusable shopping bags to reduce plastic bags.
- ♻️ Pick up your pets waste and throw in a trash can.




- Avoid watering in the afternoon. If the sun is strong, the water will evaporate before reaching the ground.
- Use a timer on your sprinkler. Over watering is wasting water.
- Adjust irrigation systems with the seasons and weather. Plants and grass need less water in the winter.

## PUBLIC PARTICIPATION

Lazy River ID meets routinely in the District. All meeting agendas are posted at the water well number two by the pavilion at least 72 hours prior to the meeting. Call 281.376.8802 for directions.



No cost option for your convenience.

<https://wdm.firstbilling.com/Account/Login.aspx?ReturnUrl=%2f>

## HAVE QUESTIONS

More information about particular health risks or contaminants may be available at:

EPA ~ 1.800.426.471

<https://safewater.zendesk.com/hc/en-us/categories/201454308-Consumer-Confidence-Reports-CCRs>

Harris County Health Department ~ 713.439.6000

<http://publichealth.harriscountytexas.gov/Services-Programs/All-Services/Drinking-Water>

Operator ~ Water District Management (WDM)

281.376.8802 ~ ~ <https://www.wdmtexas.com/>

This Report is also available online at [www.wdmtexas.com](http://www.wdmtexas.com).

## SPECIAL NOTICE FOR THE ELDERLY, INFANTS, CANCER PATIENTS, PEOPLE WITH IMMUNE PROBLEMS

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water.

Infants, some elderly, or immuno-compromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider.

Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at 1.800.426.4791.